

VOC Content Test Certificate

Wednesday, 24th August 2016

Manufacturer: Construction Chemicals Pty Ltd (49-57 Davis Street, Wingfield, SA, 5013).

Sample Description: Drymastic

Date Tested: August 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 “Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings”

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B	DRYMASTIC
General purpose adhesives and sealants: 50 grams per Litre as VOC content per material	<1 gram per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160810